



PROGRAM ADMINISTRATOR
 DEPARTMENT ALECP
 INTERTEK
 ETL SEMKO Division
 3933 U.S. ROUTE 11
 CORTLAND, NY 13045-0950

ORIGINAL ISSUE DATE: June 14, 2006

Recertification due: May 2014

An Activity Sponsored and Administered by
 Intertek

CROUSE HINDS AIRPORT LIGHTING
 PRODUCTS
 1200 Kennedy Rd.
 Windsor, CT 06095

**AIRPORT LIGHTING
 EQUIPMENT
 CERTIFICATION PROGRAM**

**CERTIFICATE OF
 CONFORMANCE**

The product described below is hereby approved for listing in the next issue of the Federal Aviation Administration (FAA) Advisory Circular (AC) 150/5345-53, Appendix 3 Addendum "Airport Lighting Equipment Certification Program. The approval is based on successful completion of tests in accordance with the specifications listed in, and the requirements for approval described in the Advisory Circular, and the reporting to the Program Administrator the results of such tests, accompanied by related documents by an Intertek recognized testing laboratory. The certification is not valid for a product modified with non-OEM replacements parts or non-production components.

L-829 – Regulators, Monitored Constant Current (AC 150/5345-10F)				
Manufacturer	Rating (kW)	Class	Style	Manufacturer's Catalog Number
Crouse Hinds ALP (Oil Cooled)	10	1	1, 2	829XX-W-11-X-66-XX-XX
	15	1	1, 2	829XX-W-15-X-66-XX-XX
	20	1, 2	1, 2	829XX-W-20-X-XX-XX-XX
	30	1, 2	1, 2	829XX-W-30-X-XX-XX-XX
	37.5	2	1, 2	82960-W-37-X-20-XX-XX
	50	2	1, 2	829XX-W-50-X-20-XX-XX

1. This Equipment requires continuing validation in accordance with the requirements of AC 150/5345-53, and the Intertek Airport Lighting Equipment Certification Program.
2. Product tested and Report issued by: Crouse Hinds ALP; Intertek

(A) Report No: 2621; 2622; 3097567CRT-001; (B) Date of Report: 5/06; 5/06; 5/06; 06/06
 3099292CRT-001

NOTE: PLEASE REVIEW, AND ADVISE ADMINISTRATOR AT INTERTEK IMMEDIATELY IF DATA, AS SHOWN, NEED TO BE CORRECTED.

Approved for Certification by:

David C. Edwards, Program Administrator
 Date: June 14, 2006