

SEQUENCE OF OPERATIONS:

LIGHTING

- 0-10V LIGHTING LOADS
- EACH LUMINAIRE INCLUDES DIMMABLE INTEGRATED SENSOR
- EACH LUMINAIRE SUPPORTS OCCUPIED/UNOCCUPIED PROGRAMMABLE LIGHT LEVELS

OCCUPANCY

- AUTOMATIC ON TO PROGRAMMABLE LEVEL
- PROGRAMMABLE UNOCCUPIED LIGHT LEVEL

DAYLIGHTING

- CONTINUOUS DIMMING
- INDIVIDUAL LUMINAIRE DAYLIGHT DIMMING
- DAYLIGHTING NOT REQUIRED FOR INDOOR SPACES

MANUAL CONTROLS

- PROGRAMMABLE ZONE/SCENE CONTROL
- OPTIONAL SCENE/RAISE/LOWER CONTROL
- ALL OFF


ADDITIONAL FEATURES

- POWER MEASUREMENT REPORTING THROUGH MOBILE APPLICATION
- AUTOMATIC DEMAND RESPONSE AVAILABLE FROM WIRELESS AREA CONTROLLER
- SCHEDULING OF PARTIAL OFF LIGHT LEVELS AND TIMES FROM WIRELESS AREA CONTROLLER
- UL924 EMERGENCY CONTROL CAPABILITIES AVAILABLE VIA LUMINAIRE BATTERY BACKUP

Bill of Materials

Qty	Catalog #	Description
1	WAC-POE	Wireless Area Controller
1	W4S-RL-W	1 Large button scene wallstation
4	WSP-MV-010	WaveLinx Relay 0-10V Switchpack
24	SSLED-LD1-24-M-UNV-840-CD2-WHT-SVPD3-U	Steeler with Integrated Sensor

TYPICAL WIRING DETAIL



Design Consideration:	Best Practice:	Best Practice:
Gateway/WAC range	150 feet to 250 feet LOS	300 feet LOS
Number of interior walls	2 walls	3 walls
Distance from WAC to 1st WCL device	150 feet	200 feet
Distance between WCL devices	75 feet	150 feet
Number of hops from WAC	4 hops	5 hops
Number of areas per WAC	16	16
Number of zones per area	3	16
Number of scenes per area	6	10

	Local Control	Manual ON	Partial ON	Bilevel Lighting	Daylight Side	Daylight Top	Partial OFF	Automatic OFF	Scheduled OFF	Receptacle Control	Energy Monitoring	Parking Garage	Functional Testing	Demand Response
ASHRAE 90.1-2016	9.4.1(a)	9.4.1.1(b)	9.4.1.1(c)	9.4.1.1(d)	9.4.1.1(e)	9.4.1.1(f)	9.4.1.1(g)	9.4.1.1(h)	9.4.1.1(i)	8.4.2	8.4.3.2	9.4.1.2	9.4.3	

