

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7125-0785:0140

Page 1 of 1

CATEGORY: 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

LISTEE: Cooper Wheelock Inc. 273 Branchport Ave, Long Branch, NJ 07740
Contact: Frank Hertzog (732) 962-7839 Fax (732) 962-7856
Email: frank.hertzog@cooperindustries.com

DESIGN: Models RSX-2415W, RSX-241575W, RSSX-2415W, RSSX-241575W, RSSX-2475W, RSSX-2430W and RSSX-24110W, RSSX-1215W, RSSX-121575W, RSSX-2415C, RSSX-2430C, RSSX-2475C and RSSX-24100C recognized component strobe lights. Model number may be followed by any two alpha/numeric characters indicating lens orientation, lettering and color. Models with Prefix RSSX- are synchronized or non-synchronized strobes. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical 20-31 VDC/FWR
Candela 15=15cd, 1575=15/75cd on axis, 30=30cd, 75=75cd, 100=100cd (ceiling), 110=110cd (Wall)
Flash rate 60 Flashes/minute

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Models with "W" are intended for wall mount only. Models with "C" are intended for ceiling mount only.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as recognized component strobe lights suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For indoor use only. For synchronization strobes, Models SM-12/24, SMX-12/24, DSM-12/24 or DSMX-12/24 Sync Control Module (CSFM Listing No. 7300-0785:132) must be used.

NOTE:

*Rev. 06-13-06



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division