

**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM**



# LISTING SERVICE

**LISTING No.** 7125-0785:0141  
**CATEGORY:** 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

Page 1 of 2

**LISTEE:** Cooper Wheelock Inc. 273 Branchport Ave, Long Branch, NJ 07740  
Contact: Frank Hertzog (732) 962-7839 Fax (732) 962-7856  
Email: frank.hertzog@cooperindustries.com

**DESIGN:** Synchronized or non-synchronized Strobe Lights. Models are as follows:

<u>RSS-##W</u>	<u>RSSP-##W</u>	<u>RSS-##C</u>	<u>RSSP-##C</u>	<u>RSS-##CR</u>	<u>RSSP-##CR</u>
2415	2415	2415	2415	2415	2415
2475	2475	2430	2430	2430	2430
241575	241575	2475	2475	2475	2475
2430	2430	*2495	*2495	*2495	*2495
24110	24110				
1215	1215				
121575	121575				

Also, Models RSS-24MCW and RSSP-24MCW, RSS-24MCC, RSS-24MCCR, RSSP-24MCC, RSS-24MCWH, RSS-24MCWHR, RSSP-24MCWH, RSS-24MCCH, RSS-24MCCHR, RSSP-24MCCH, \*ZRS-MCC, \*ZRS-MCW, \*ZRS-MCCH and \*ZRS-MCWH. Model numbers may be followed by any two alpha/numeric character indicating lens orientation, lettering and color. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Electrical 12 = 8-17.5VDC/FWR OR 24 =16-33VDC/FWR  
Candela 15=5cd,1575=15/75cd on axis,30=30cd,75=75cd, 110=110cd(Wall)  
RSS-24MCW,RSSP-24MCW,\*ZRS-MCW:Selectable 15cd,30cd,75cd  
or110cd  
RSS-24MCC,RSS-24MCCR,RSSP-24MCC,\*ZRS-MCC:Selectable  
15cd,30cd,75cd and 95cd  
RSS-24MCWH,RSS-24MCWHR,RSSP-24MCWH,\*ZRS-MCWH:Selectable  
135cd,185cd  
RSS-24MCCH,RSS-24MCCHR,RSSP-24MCCH,\*ZRS-MCCH:Selectable  
115cd,177cd  
Flash rate 60 flashes/minute

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Models with suffix -W, wall mount only. Models with suffix -C, ceiling mount only. All models are for indoor use only.

**MARKING:** Listee's name, model number, electrical/candela rating, and UL label.

**APPROVAL:** Listed as strobe light suitable for the hearing impaired when used with separately listed electrically compatible fire alarm control units. For synchronization strobes, Models

\*Rev. 12-13-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**  
*Fire Engineering Division*

SM-12/24, SMX-12/24, DSM-12/24 or DSMX-12/24 Sync Control Module (CSFM Listing No. 7300-0785:132) must be used. Refer to listee's Installation Instruction Manual for details.

\*Rev. 12-13-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

*Listing Expires* **June 30, 2012**

Authorized By: **FRANCIS MATEO**, Program Coordinator  
*Fire Engineering Division*