

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0785:0154

Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Cooper Wheelock Inc. 273 Branchport Ave, Long Branch, NJ 07740
Contact: Frank Hertzog (732) 962-7839 Fax (732) 962-7856
Email: frank.hertzog@cooperindustries.com

DESIGN: Models RSSWP-2475W and RSSWP-2475C synchronous or non-synchronous strobe light. Model may be followed by two alpha or numeric characters indicating lettering and color, followed by W for wall mount or C for ceiling mount. Refer to listee's data sheet for additional detailed product description and operational considerations.
Models RSSWP-24MCWH (wall mount) & RSSWP-24MCCH (ceiling mount) audible/strobes for the hearing impaired followed by two alpha/numeric characters indicating lens lettering and product color.

RATING: Electrical: 16-33 VDC/VFWR
Flash rate: 60 flashes/min.

Candela:	RSSWP-2475W	30cd (115cd at-40 C)
	RSSWP-2475C	30cd (115cd at-40 C)
	RSSWP-24MCWH Selectable	135/185cd (65/90cd at-40 C)
	RSSWP-24MCCH Selectable	115/177cd (50/75cd at-40 C)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Model can be used outdoors when used with WPSBB back box only.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a strobe light for use with separately listed electrically compatible fire alarm control units. For indoor or outdoor use. Intended for wall mount or ceiling mount. Lens color may be white, red, blue, green or amber.

For synchronized strobes, Models SM-12/24, SMX-12/24 Sync Modules, DSM-12/24 or DSMX-12/24 Duel Sync Modules (CSFM Listing No. 7300-0785:1323) or power supply PS-12/24-8 (CSFM Listing No. 7315-0785:149) must be used.

NOTE:

*Rev. 10-01-07



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division