

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7320-0785:0144

Page 1 of 1

CATEGORY: 7320 -- SPEAKERS

LISTEE: Cooper Wheelock Inc. 273 Branchport Ave, Long Branch, NJ 07740
Contact: Frank Hertzog (732) 962-7839 Fax (732) 962-7856
Email: frank.hertzog@cooperindustries.com

DESIGN: Models STH-15S and STH-15SR speakers. Suitable for outdoor use. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as speakers for use with separately listed compatible fire alarm control units. If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE:

*Rev. 06-13-06



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division