

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7125-0785:0151

Page 1 of 1

CATEGORY: 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

LISTEE: Cooper Wheelock Inc. 7246 16th St. E., Ste. 105, Sarasota, FL 34243
Contact: Tom Conover (941) 487-2336
Email: thomas.conover@cooperindustries.com

DESIGN: Models CH70-24MCW, CH70-24MCC, CH70-24MCWH, CH70-24MCCH, *CH70-241575W, CH90-24MCW, CH90-24MCC, CH90-24MCWH, CH90-24MCCH and *CH90-241575W synchronized or non-synchronized multi-candela chime strobes. Units may be followed by suffixes to designate lens orientation, lens lettering and plate color. Models with suffix -W or WH are wall mount, -C or CH are ceiling mount. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 16-33 VDC
Flash rate: 60 flashes/min
Candela: Selectable:
MCW = 15cd, 30cd, 75cd or 110cd
MCC = 15cd, 30cd, 75cd or 95cd
MCWH = 135cd, 185cd
MCCH = 115cd, 177cd
*1575 = 15cd/75 cd on axis

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction. For indoor use on a wall or ceiling.

MARKING: Listee's name, model number, electrical/candela rating, and UL label.

APPROVAL: Listed as chime strobes suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For synchronized strobes, Models SM-12/24 and DSM-12/24 sync control module must be used. Refer to listee's Installation Instruction Manual for details.

*Rev. 07-30-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division