

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 6911-0785:0157
CATEGORY: 6911 -- VOICE COMMUNICATION SYSTEMS CONTROL UNITS

Page 1 of 2

LISTEE: Cooper Wheelock Inc. 7246 16th St. E., Ste. 105, Sarasota, FL 34243
Contact: Tom Conover (941) 487-2336
Email: thomas.conover@cooperindustries.com

DESIGN: Model SP40S voice evacuation unit. Unit does not sense an emergency condition, but when initiated from a control unit, can provide pre-recorded messages and/or live voice messaging via a local microphone. The SP40S also features night ring (NR), telephone paging (TEL) and background music (BGM) which are not operational during alarm conditions. These features will not operate if the system is only powered by a secondary source. System components:

BATC-B,-R	Battery Enclosure
NACIM	Notification Circuit Interface Module
SP40S	Multi-function Facility Communication System
*SP40SE	Multi-function Facility Communication System
*SP40S-D	Multi-function Facility Communication System
*SP40SE-D	Multi-function Facility Communication System
MIC 400	Local Microphone
SP40/2	Enclosure Enclosure Backbox
SPRM	Safepath Remote Microphone
SPRM-GP	SAFEPATH 4 Remote Microphone, Non-Fire Application
SP4-RMX	Remote Microphone Expansion Module
SP4-APS	Addressable Paging Splitter
SP-SVC	Supervised Volume Control Module
SP4Z-B	4 Zone Class B Speaker Audio Splitter
SPB-320,SPB-160,SPB-80/4	Audio Boosters
SP4Z-A/B	2 Zone Class A, 4 Zone Class B Audio Splitter
SPMB-4Z	Mounting Bracket

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: SP40S (-D) *SP40SE (-D) SPB-160 SPB-80/4
Primary: 120 VAC, 2.4A *240 VAC, 1.5A 160W Audio 80 W, Audio
Secondary: 24 VDC, 4.3A 24 VDC, 2A NAC Circuit

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

*Rev. 11-29-11 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division

APPROVAL: Listed as voice evacuation unit when used in conjunction with separately listed electrically and functionally compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

NOTE: The telephone paging is not to be used for emergency use.

*Rev. 11-29-11 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division