

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7125-0785:0160
CATEGORY: 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

Page 1 of 1

LISTEE: Cooper Wheelock Inc. 7246 16th St. E., Ste. 105, Sarasota, FL 34243
Contact: Tom Conover (941) 487-2336
Email: thomas.conover@cooperindustries.com

DESIGN: Model AMT-241575W, AMT-2475W, and *AMT-24MCW may be followed by -NYC, followed by two alphanumeric characters indicating lettering and product color. Model AMT have a high and low output and provide a selectable setting for one tone of nine possible tones. Model number may be followed by two alpha/numeric characters indicating lens orientation, lettering and color. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 24V = 16 - 33 VDC
Strobe Candela: 1575W = 15cd with 75cd on axis, 75W = 75cd, wall mount only
MCW=15cd, 30cd, 75cd or 110cd
Flash rate : 60 flashes per minute

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to authority having jurisdiction. Models with -W are intended for wall mount only.

MARKING: Listee's name, model number, electrical/candela rating, and UL label.

APPROVAL: Listed as audible/visual signal devices suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For indoor use only. For synchronization, Sync Modules SM-12/24 or SMX-12/24, Dual Sync Modules DSM-12/24 or DSMX-12/24 (CSFM Listing No. 7300-0785:132) must be used. Refer to listee's Installation Instruction Manual for details.

These appliances can produce a distinctive three pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

*Rev. 06-13-06



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division