

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7320-0785:0171

Page 1 of 1

**CATEGORY:** 7320 -- SPEAKERS

**LISTEE:** Cooper Wheelock Inc. 7246 16th St. E., Ste. 105, Sarasota, FL 34243  
Contact: Tom Conover (941) 487-2336  
Email: thomas.conover@cooperindustries.com

**DESIGN:** Models E60H, E70H, E90H high-fidelity speakers followed by suffix R (red) or W (white).  
Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 25 or 70 Vrms

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as speakers for use with separately listed electrically compatible fire alarm control units. For indoor use only.

07-23-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division