

CERTIFICATE OF COMPLIANCE

Certificate Number 20180122-E5946
Report Reference E5946-20170428
Issue Date 2018-JANUARY-22

Issued to: COOPER WHEELOCK INC
273 BRANCHPORT AVE
LONG BRANCH NJ 07740-6830

**This is to certify that
representative samples of**

AUDIBLE-SIGNAL APPLIANCES; SIGNALING
APPLIANCES AND EQUIPMENT FOR THE HEARING
IMPAIRED; VISUAL-SIGNAL APPLIANCES FOR FIRE-
PROTECTIVE SIGNALING SYSTEMS

See Addendum

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 464, AUDIBLE SIGNALING DEVICES FOR FIRE
ALARM AND SIGNALING DEVICES, INCLUDING
ACCESSORIES
UL 1638, VISIBLE SIGNALING DEVICES FOR FIRE
ALARM AND SIGNALING SYSTEMS, INCLUDING
ACCESSORIES
UL 1480, FIRE ALARM AND SIGNALING SYSTEMS,
INCLUDING ACCESSORIES

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180122-E5946
Report Reference E5946-20170428
Issue Date 2018-JANUARY-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Horn: Model LHNR3, LHNW3, LHNRC3 and LHNWC3, may be followed by a suffix representing lettering, mounted on a wall or ceiling, intended for indoor use only.

Strobe Light: Model LSTR3 and LSTW3, may be followed by a suffix representing lettering. Synchronous or non synchronous, mounted on a wall, intended for indoor use only.

Strobe Light: Model LSTRC3 and LSTWC3, may be followed by a suffix representing lettering. Synchronous or non synchronous, mounted on a ceiling, intended for indoor use only.

Horn/Strobe Light: Model LHSR3 and LHSW3, may be followed by a suffix representing lettering. Synchronous or non synchronous. Mounted on a wall. Intended for indoor use only.

Horn/Strobe Light: Model LHSRC3 and LHSWC3, may be followed by a suffix representing lettering. Synchronous or non synchronous, mounted on a ceiling. Intended for indoor use only.

Strobe Light: Model LSTR3 and LHSW3, followed by a suffix representing lettering, followed by a suffix representing lens color. Synchronous or non synchronous, mounted on a wall. Intended for Private Mode Emergency Use, indoor use only.

Strobe Light: Model LSTRC3 and LHSWC3, followed by a suffix representing lettering, followed by a suffix representing lens color (A for amber, B for blue). Synchronous or non synchronous, mounted on a ceiling. Intended for Private Mode Emergency Use, indoor use only.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180122-E5946
Report Reference E5946-20170428
Issue Date 2018-JANUARY-22

Issued to: COOPER WHEELOCK INC
273 BRANCHPORT AVE
LONG BRANCH NJ 07740-6830

**This is to certify that
representative samples of**

VISUAL AND VISUAL-AUDIBLE SIGNAL APPLIANCES,
FIRE ALARM, INCLUDING ACCESSORIES; AUDIBLE
SIGNAL APPLIANCES, FIRE ALARM, INCLUDING
ACCESSORIES

See Addendum

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

CAN/ULC S525, AUDIBLE SIGNAL DEVICES FOR FIRE
ALARM SYSTEMS


CAN/ULC S526, VISIBLE SIGNALING DEVICES FOR
FIRE ALARM AND SIGNALING SYSTEMS, INCLUDING
ACCESSORIES

CAN/ULC S541:2016, SPEAKERS FOR FIRE ALARM AND
SIGNALING SYSTEMS, INCLUDING ACCESSORIES

Additional Information:


See the ULC Online Certification Directory at www.ulc.ca
for additional information

Only those products bearing the ULC Listing Mark should be considered as being covered by ULC's
Listing and Follow-Up Service.

The ULC Listing Mark generally includes the following elements: the symbol ULC in a circle:  with
the word "LISTED"; a control number (may be alphanumeric) assigned by ULC; and the product
category name (product identifier) as indicated in the appropriate ULC Directory.

To confirm the status, validate the above information via the online directory.

Look for the ULC Listing Mark on the product.



Joseph Hosey, General Manager, Director of Sales - Canada

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized
licensee of ULC. For questions, please contact a local ULC Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180122-E5946
Report Reference E5946-20170428
Issue Date 2018-JANUARY-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current ULC requirements.

Horn: Model LHNR3, LHNW3, LHNRC3 and LHNWC3, may be followed by a suffix representing lettering, mounted on a wall or ceiling, intended for indoor use only.

Strobe Light: Model LSTR3 and LSTW3, may be followed by a suffix representing lettering. Synchronous or non synchronous, mounted on a wall, intended for indoor use only.


Strobe Light: Model LSTRC3 and LSTWC3, may be followed by a suffix representing lettering. Synchronous or non synchronous, mounted on a ceiling, intended for indoor use only.

Horn/Strobe Light: Model LHSR3 and LHSW3, may be followed by a suffix representing lettering. Synchronous or non synchronous. Mounted on a wall. Intended for indoor use only.

Horn/Strobe Light: Model LHSRC3 and LHSWC3, may be followed by a suffix representing lettering. Synchronous or non synchronous, mounted on a ceiling. Intended for indoor use only.

Strobe Light: Model LSTR3 and LHSW3, followed by a suffix representing lettering, followed by a suffix representing lens color. Synchronous or non synchronous, mounted on a wall. Intended for Private Mode Emergency Use, indoor use only.

Strobe Light: Model LSTRC3 and LHSWC3, followed by a suffix representing lettering, followed by a suffix representing lens color (A for amber, B for blue). Synchronous or non synchronous, mounted on a ceiling. Intended for Private Mode Emergency Use, indoor use only.



Joseph Hosey, General Manager, Director of Sales - Canada

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized licensee of ULC. For questions, please contact a local ULC Customer Service Representative at <http://ul.com/aboutul/locations/>

