

April 28, 2017

Cooper Wheelock Inc
Mr. Leon Newsome
7246 16th Street East, Suite 105
Sarasota, FL 34243


Subject: Wheelock Exceder LED3: LHS3, LST3, LHN3, LSPST3, LFHNK3 and LFHSK3 Series Compatibility

Dear Mr. Newsome,

This letter is to confirm that the Wheelock Exceder LED3 product line referenced above has been investigated and found to meet the 2016 Edition of NFPA 72 for the maximum pulse width of 20 millisecond. In addition, the Wheelock Exceder LED3 product line has been found to be reverse compatible with the Wheelock model RSS Strobe based products including the RSS, CH, E, EH, ET,ST,HS,MT,S8, SA, STH and Z Series. Any established compatibility of the RSS Strobe based products with any Fire Alarm Control Panel(s) and accessories also extends to the Exceder LED3 series strobes. When installed in accordance with the Wheelock Exceder LED3's installation instructions, the Wheelock Exceder LED3 series can support up to a maximum of 105 LED3 devices per Notification Appliance Circuit.

The listing of the Exceder LED3 Series also includes the ability to install the strobes in the same notification zone and field of view with any RSS Strobe based product.

Sincerely



Dan Grosch

Senior Staff Engineering Associate

Daniel.M.Grosch@UL.com

