

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180122-E5946  
**Report Reference** E5946-20170429  
**Issue Date** 2018-JANUARY-22

**Issued to:** COOPER WHEELOCK INC  
273 BRANCHPORT AVE  
LONG BRANCH NJ 07740-6830

**This is to certify that representative samples of** AUDIBLE-SIGNAL APPLIANCES; SIGNALING APPLIANCES AND EQUIPMENT FOR THE HEARING IMPAIRED

See Addendum

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 464, AUDIBLE SIGNALING DEVICES FOR FIRE ALARM AND SIGNALING DEVICES, INCLUDING ACCESSORIES  
UL 1638, VISIBLE SIGNALING DEVICES FOR FIRE ALARM AND SIGNALING SYSTEMS, INCLUDING ACCESSORIES

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180122-E5946  
**Report Reference** E5946-20170429  
**Issue Date** 2018-JANUARY-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Horn: Model LFHNKR3 and LFHNKW3, may be followed by a suffix representing lettering, intended for indoor use only, mounted on a wall or ceiling.

Horn/Strobe Light: Model LFHSKR3 and LFHSKW3, may be followed by a suffix representing lettering, synchronous or non synchronous horn/strobe, intended for indoor use only, mounted on a wall.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180122-E5946  
**Report Reference** E5946-20170429  
**Issue Date** 2018-JANUARY-22

**Issued to:** COOPER WHEELOCK INC  
273 BRANCHPORT AVE  
LONG BRANCH NJ 07740-6830

**This is to certify that  
representative samples of**

VISUAL AND VISUAL-AUDIBLE SIGNAL APPLIANCES,  
FIRE ALARM, INCLUDING ACCESSORIES; AUDIBLE  
SIGNAL APPLIANCES, FIRE ALARM, INCLUDING  
ACCESSORIES

See Addendum

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:**

CAN/ULC S525, AUDIBLE SIGNAL DEVICES FOR FIRE  
ALARM SYSTEMS  
CAN/ULC S526, VISIBLE SIGNALING DEVICES FOR  
FIRE ALARM AND SIGNALING SYSTEMS, INCLUDING  
ACCESSORIES

**Additional Information:**


See the ULC Online Certification Directory at [www.ulc.ca](http://www.ulc.ca)  
for additional information

Only those products bearing the ULC Listing Mark should be considered as being covered by ULC's  
Listing and Follow-Up Service.

The ULC Listing Mark generally includes the following elements: the symbol ULC in a circle:  with  
the word "LISTED"; a control number (may be alphanumeric) assigned by ULC; and the product  
category name (product identifier) as indicated in the appropriate ULC Directory.

To confirm the status, validate the above information via the online directory.

Look for the ULC Listing Mark on the product.



Joseph Hosey, General Manager, Director of Sales - Canada

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized  
licensee of ULC. For questions, please contact a local ULC Customer Service Representative at <http://ul.com/aboutul/locations/>




# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180122-E5946  
**Report Reference** E5946-20170429  
**Issue Date** 2018-JANUARY-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current ULC requirements.

Horn: Model LFHNKR3 and LFHNKW3, may be followed by a suffix representing lettering, intended for indoor use only, mounted on a wall or ceiling.

Horn/Strobe Light: Model LFHSKR3 and LFHSKW3, may be followed by a suffix representing lettering, synchronous or non synchronous horn/strobe, intended for indoor use only, mounted on a wall.



Joseph Hosey, General Manager, Director of Sales - Canada

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized licensee of ULC. For questions, please contact a local ULC Customer Service Representative at <http://ul.com/aboutul/locations/>

