

CERTIFICATE OF COMPLIANCE

Certificate Number 20150721-S2652
Report Reference S2652-20140219
Issue Date 2015-JULY-21

Issued to: COOPER WHEELOCK INC
273 BRANCHPORT AVE
LONG BRANCH NJ 07740

**This is to certify that
representative samples of**

SPEAKERS AND AMPLIFIERS FOR FIRE-PROTECTIVE
SIGNALING SYSTEMS; VISUAL AND VISUAL-AUDIBLE
SIGNAL APPLIANCES, FIRE ALARM, INCLUDING
ACCESSORIES; SIGNALING APPLIANCES AND
EQUIPMENT FOR THE HEARING IMPAIRED, VISUAL-
SIGNAL APPLIANCES FOR FIRE PRETECTIVE
SIGNALING SYSTEMS; SPEAKERS AND SPEAKERS
AND ACCESSORIES FOR FIRE ALARM SYSTEMS
See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1638, Visual Signaling Appliances – Private-Mode
Emergency and General Utility Signaling.
UL 1971, Signaling Devices for the Hearing Impaired.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20150721-S2652
Report Reference S2652-20140219
Issue Date 2015-JULY-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Products Covered:

Ceiling Speaker Strobe Model: LSPSTxC

Ceiling Speaker Strobe Model: LSPSTxC-A

The letter 'x' indicates product color. The model number may be followed by a hyphen and up to three alphanumeric characters indicating lettering. An "A" on the end indicates amber lens.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20150721-S2652
Report Reference S2652-20140219
Issue Date 2015-JULY-21

Issued to: COOPER WHEELOCK INC
273 BRANCHPORT AVE
LONG BRANCH NJ 07740

**This is to certify that
representative samples of**


SPEAKERS AND AMPLIFIERS FOR FIRE-PROTECTIVE
SIGNALING SYSTEMS; VISUAL AND VISUAL-AUDIBLE
SIGNAL APPLIANCES, FIRE ALARM, INCLUDING
ACCESSORIES; SIGNALING APPLIANCES AND
EQUIPMENT FOR THE HEARING IMPAIRED, VISUAL-
SIGNAL APPLIANCES FOR FIRE PRETECTIVE
SIGNALING SYSTEMS; SPEAKERS AND SPEAKERS
AND ACCESSORIES FOR FIRE ALARM SYSTEMS
See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: CAN/ULC-S526-07, Visible Signal Devices For Fire Alarm
Systems, Including Accessories.
CAN/ULC-S541, Speakers for Fire Alarm Systems.


Additional Information: See the ULC Online Certification Directory at www.ulc.ca
for additional information

Only those products bearing the ULC Listing Mark should be considered as being covered by ULC's
Listing and Follow-Up Service.

The ULC Listing Mark generally includes the following elements: the symbol ULC in a circle:  with
the word "LISTED"; a control number (may be alphanumeric) assigned by ULC; and the product
category name (product identifier) as indicated in the appropriate ULC Directory.

To confirm the status, validate the above information via the online directory.

Look for the ULC Listing Mark on the product.



Joseph Hosey, General Manager, Director of Sales - Canada

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized
licensee of ULC. For questions, please contact a local ULC Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20150721-S2652
Report Reference S2652-20140219
Issue Date 2015-JULY-21


This is to certify that representative samples of the product as specified on this certificate were tested according to the current ULC requirements.

Products Covered:

Ceiling Speaker Strobe Model: LSPSTxC

Ceiling Speaker Strobe Model: LSPSTxC-A

The letter 'x' indicates product color. The model number may be followed by a hyphen and up to three alphanumeric characters indicating lettering. An "A" on the end indicates amber lens.



Joseph Hosey, General Manager, Director of Sales - Canada

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized licensee of ULC. For questions, please contact a local ULC Customer Service Representative at <http://ul.com/aboutul/locations/>

