



NOTICE OF COMPLETION
AND
AUTHORIZATION TO APPLY THE UL MARK

02/18/2014

Cooper Wheelock Inc
Mr. THOMAS CONOVER
273 Branchport Ave
Long Branch Nj 07740-6830, United States

Our Reference: File E5946 Volume 37, 38; File S2652 Volume 11, 12, 13, 14 Project Number 4786183648
Your Reference: Conover T.
Project Scope: Audible Signal

Dear Mr. THOMAS CONOVER:

Congratulations! UL's investigation of your product(s) has been completed under the above Reference Number and the product was determined to comply with the applicable requirements. This letter temporarily supplements the UL Follow-Up Services Procedure and serves as authorization to apply the UL Mark at authorized factories under UL's Follow-Up Service Program. To provide your manufacturer(s) with the intended authorization to use the UL Mark, you must send a copy of this notice to each manufacturing location currently authorized under File E5946 Volume 37, 38; File S2652 Volume 11, 12, 13, 14.

Records in the Follow-Up Services Procedure covering the product are now being prepared and will be sent in the near future. Until then, this letter authorizes application of the UL Mark for 90 days from the date indicated above.

Additional requirements related to your responsibilities as the Applicant can be found in the document "Applicant responsibilities related to Early Authorizations" that can be found at the following web-site:
<http://www.ul.com/EAResponsibilities>

Any information and documentation provided to you involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

We are excited you are now able to apply the UL Mark to your products and appreciate your business. Feel free to contact me or any of our Customer Service representatives if you have any questions.

Very truly yours,

Michael T. Silerzio
847-664-2419
Engineering Associate
Michael.T.Silerzio@ul.com

Reviewed by:

William R. Carney
847/664-1088
Chief Engineer Director I
William.R.Carney@ul.com

NBKD7CB-88C4C4

Information pertaining to the California State Fire Marshal Listing Process

Testing Laboratory: Underwriters Laboratories Inc
333 Pfingsten Road
Northbrook, IL 60062
Tel: (847) 272-8800
Fax: (847) 272-8129

Project Number: 4786183648

File Number: E5946, Volume 37, 38;
S2652, Volume 11, 12, 13, 14

Applicable Standards: UL 464, 9th Edition; UL 1971 3rd Edition; UL 1480, 6th Edition;
California Amendments: None

Responsible Engineer: Michael Silerzio
Tel: (847) 664-2419
Underwriters Laboratories Inc

Report Date: TBD

CFSM Listee: Cooper Wheelock Inc.
273 Branchport Ave
Long Branch NJ 07740
Contact: Tom Conover
Tel: 1-941-487-2336

Product Description: Horn: Model Exceder LED Series LHNxC horn, intended for indoor use only, mounted on a wall or ceiling.

Strobe Light: Model Exceder LED Series LSTxC synchronous or non-synchronous strobe, intended for indoor use only, mounted on a ceiling.

Horn/Strobe Light: Model Exceder LED Series LHSxC synchronous or non-synchronous horn/strobe, intended for indoor use only, mounted on a ceiling.

Speaker: Model Exceder Series LSPKxC intended for indoor use only, mounted on a ceiling.

Speaker/Strobe: Model Exceder Series LSPSTxC intended for indoor use only, mounted on a ceiling.

Rating: The electrical ratings for each assembly are covered in the report, and shall be listed in the manufacturer's installation instructions.

Installation: In accordance with the Listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

Marking: Listee's name, model number, minimum and maximum electrical rating, The minimum sound pressure level rating in dB at 10 ft. The tone and candela setting shall be marked with their level. When a visible signaling appliance employs a select switch, multi-tap connector, or other selection means for different light intensity outputs, the unit shall be marked with the light intensity value and operating current for each position. Each audible signal device shall be legibly and permanently marked at a location that is visible after installation with the wording "FIRE ALARM DEVICE - DO NOT PAINT". The dimension of all letters shall be a minimum of 1.6 mm. Model LST with amber colored strobe lens is to be marked:

"WARNING – Not to be used as a Visual Public Mode Alarm Notification Appliance."

Approval: Listed as: Audible-signal Appliances, General Signal, and /or Signaling Appliances and Equipment for the Hearing Impaired, and /or Visual-Signal Appliances For Fire-Protective Signaling Systems., and/or speakers and Amplifiers for Fire Protective Signaling Systems. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.